

2430 "E" Street, N. W.
Washington, D. C.
21 August 1953

25X1A9a

25X1A9a

Dear Mr. [REDACTED]:

Referring to your letter of 4 August 1953 reference same subject, please be advised as follows:

Fixture B proposal is satisfactory, except that Type A-44 should be substituted for Type A-22.

Fixture H proposal is regarded by the Engineers as much less satisfactory than that specified. Enclosed is cut showing the [REDACTED] item for your information. Note that the lamps are more completely housed and that the head arrangement allows universal beam adjustment.

25X1A

Your letter makes no reference to fixture J and K, cuts of which were enclosed. These fixtures are acceptable, subject to their meeting size requirements specified.

Very truly yours,

25X1A9a

Enclosure